

„ Georgian Water and Power “

ASSESSMENT OF HEALTH AND SAFETY CONDITIONS AND PLANNING OF IMPROVEMENT MEASURES AT THE KHRAMI SECOND ELEVATION PUMPING STATION AND CHLORINATION FACILITY PREMISES AND WORK AREAS




DOCUMENT PREPARED BY: SHORENA KIKNADZE
(LABOR SAFETY SPECIALIST)

PERSONS RESPONSIBLE FOR IMPLEMENTATION:
ALEXANDER MAGHRADZE
ARIZ GARAEV

21.05.2025

Georgian Water and Power



#	Event	Photo	Action
---	-------	-------	--------

	<p>Finding: In the pumping station machine hall, the floor is uneven, has multiple holes, and is covered with unstable metal sheets, which may cause an employee or other person to trip, fall into a hole, and sustain related injuries.</p>		<p>The floor of the work area must not be slippery or hazardous due to an uneven surface; at the same time, it must be solid, without holes, slopes, or protrusions. <i>(Government of Georgia Decree No. 341 July 1, 2022 Article 5, Paragraph 2.)</i></p>
			
			

Georgian Water and Power

		
		
<p>Finding: The windows in the pumping station have cracked glass; in the event of falling, it may cause physical injury to employees or other persons. Additionally, it may result in disruption of climate control.</p>		<p>Replace/repair the damaged glass panes.</p>

Georgian Water and Power

		
<p>Finding: There is no railing installed on the upper balcony of the pumping station machine hall.</p>		<p>Protective railings/guardrails/handrails must be installed wherever there is a potential risk of falling from height; <i>(Government of Georgia Decree No. 477 October 27, 2017 Article 5, Paragraph a)</i></p> <p>2. Ramps with a height exceeding 1 meter must be equipped with protective railings. <i>(Government of Georgia Decree No. 477 October 27, 2017 Article 10, Paragraph 4)</i></p>
		

Georgian Water and Power



Georgian Water and Power

Finding:

The electrical equipment and wiring do not comply with standards, which may cause a fire.



Electrical equipment and wiring must be designed and installed in compliance with the relevant regulatory standards so that the work area is properly protected from fire and explosion hazards.”

(Government of Georgia

Decree No. 341

July 1, 2022

Article 3, Paragraph 1)

Georgian Water and Power

Finding:

There is no properly arranged restroom on or near the pumping station premises.



1. Restrooms of the required number must be provided at the workplace, near rest and changing rooms, showers, and washbasins.

2. Restrooms must be equipped with an exhaust or ventilation system and washbasins.

(Government of Georgia

Decree No. 341

July 1, 2022

Article 18, Paragraphs 1 and 4)