




① DEMOLITION PLAN - SIXTH FLOOR #607-AR-002
1/100




② NEW CONSTRUCTION PLAN - SIXTH FLOOR #607-AR-002
1/100

- Demolition of grid suspended ceiling- total 6.3m2
- Demolition of equipment on the ceiling
 - 30*50(2m) duct
 - 30*30(2m) duct
 - 1 60*60 LED Lighting fixture
- Demolition of plasterboard walls in front of the shafts.(2X267*240cm)
- Construction of new EI120 shaft walls-2*25mm manufactured from one side-(2X267*240cm)
- Construction of new EI60 compartment wall-2*12.5mm manufactured from both sides, see wall detail. (240*240cm)
- Provide a new double-leaf, EI45 fire door (150*210cm) to the compartment wall.
- Install fire dampers on ducts (2m)
- Firestopping around the cavities of the ducts.
- Mounting new grid suspended ceiling- total 6.3m2
 - 30*50(2m) duct
 - 30*30(2m) duct
 - 1 60*60 LED Lighting fixture
- Reassembling of equipment on the ceiling
- Repairing of vinly tiling on the floor of the parts which are damaged while demolishing the walls.


LEGEND AND MATERIAL LIST	
SYMBOL	DESCRIPTION
	TO BE DEMOLISHED 60*60 GRID SUSPENDED CEILING
	TO BE MOUNTED 60*60 GRID SUSPENDED CEILING
	TO BE DEMOLISHED PVC HYGIENIC SUSPENDED CEILING
	TO BE MOUNTED PVC HYGIENIC SUSPENDED CEILING
	TO BE DEMOLISHED PLASTERBOARD SUSPENDED CEILING
	TO BE MOUNTED PLASTERBOARD SUSPENDED CEILING
	TO BE CLOSED HOLE BY BMS WALL
	TO BE DEMOLISHED EXISTING PLASTERBOARD WALL
	TO BE DEMOLISHED EXISTING CERAMIC TILE
	TO BE CONSTRUCTED PLASTERBOARD WALL WITHOUT FIRE RATING
	TO BE CONSTRUCTED CERAMIC TILE
	TO BE CONSTRUCTED COMPARTMENT WALL FOR FIRE SEPARATION EI60- 2x12,5 mm /from both sides
	TO BE CONSTRUCTED SHAFT WALL FOR FIRE SEPARATION EI120 - Shaft Wall 2x25 mm Flameboard/from one side
	TO BE CONSTRUCTED WALL FOR FIRE SEPARATION EI120 - 2x15 mm/from both sides
	TO BE CONSTRUCTED WALL FOR FIRE SEPARATION EI60 - 2x15 mm Plasterboard/from one side
	TO BE CONSTRUCTED HALL WALL FOR FIRE SEPARATION EI60 - One Layer
	TO BE DEMOLISHED EXISTING DOOR
	TO BE MOUNTED NEW FIRE DOOR
	TO BE REMOUNTED EXISTING DOOR



③ PHOTOGRAPHS OF CURRENT SITUATION - SIXTH FLOOR #607-AR-002



④ SHAFT WALL DETAIL FOR FIRE SEPARATION EI120/from one side



⑤ COMPARTMENT WALL DETAIL FOR FIRE SEPARATION EI60/from both sides

KEY PLAN		
FOR SYSTEM APPROVAL FOR TENDER FOR INSTALLATION AS BUILT		
Date	For System Approval	
Explanation		
CLIENT 		
DESIGNER TASARIM, DANIŞMANLIK VE EĞİTİM HİZMETLERİ LTD.ŞTİ. Cetin EMEC Bulvarı 2. Cad. No : 37/4 A. ÖVEÇLER - 06460 ANKARA / TÜRKİYE Tel : +90-312-472 62 88 Faks : +90-312-472 62 89 e-posta: info@karina.gen.tr		
TECH. CONSULTANCY : KARİNA	FIRE & LIFE SAFETY IMPROVEMENT OF FIRE& SMOKE COMPARTMENT FEATURES DRAWINGS	
SYSTEM DESIGN : KARİNA		
MATERIAL SUPPLY : -		
INSTALLATION : -		
APPROVAL : -	DRAWING NO : EVEX-SNS-KAR-604-606-607-AR-002	REV. 00
DATE : 08.11.2020		* / *
SCALE : 1/100	FILE NAME : C:\EVEX-SNS-KAR-604-606-607-AR-	