




① DEMOLITION PLAN - FIRST FLOOR #105-AR-002  
1/100



② NEW CONSTRUCTION PLAN - FIRST FLOOR #105-AR-002  
1/100



(Hall in front of the elevator and the exit door)



(Existing exit door)

③ PHOTOGRAPHS OF CURRENT SITUATION - FIRST FLOOR #105-AR-003

1. Demolition of plasterboard walls from both sides of the door(2X 35\*225cm).
2. Demolition of plasterboard ceiling on top of the door(35\*140cm)
3. Demolition of steel exit door(140\*220cm)
4. Providing new door with panic bar (140\*220cm)
5. Mounting new plasterboard walls instead of the dismantled ones at the both sides of the door.
6. Mounting new plasterboard ceiling instead of the dismantled one.
7. Repairing of vinyl tiling on the floor of the parts which are damaged while demolishing the walls.

LEGEND AND MATERIAL LIST	
SYMBOL	DESCRIPTION
	TO BE DEMOLISHED 60*60 GRID SUSPENDED CEILING
	TO BE MOUNTED 60*60 GRID SUSPENDED CEILING
	TO BE DEMOLISHED PVC HYGIENIC SUSPENDED CEILING
	TO BE MOUNTED PVC HYGIENIC SUSPENDED CEILING
	TO BE DEMOLISHED PLASTERBOARD SUSPENDED CEILING
	TO BE MOUNTED PLASTERBOARD SUSPENDED CEILING
	TO BE CLOSED HOLE BY BMS WALL
	TO BE DEMOLISHED EXISTING PLASTERBOARD WALL
	TO BE DEMOLISHED EXISTING CERAMIC TILE
	TO BE CONSTRUCTED PLASTERBOARD WALL WITHOUT FIRE RATING
	TO BE CONSTRUCTED CERAMIC TILE
	TO BE CONSTRUCTED COMPARTMENT WALL FOR FIRE SEPARATION E120 - 2x12,5 mm /from both sides
	TO BE CONSTRUCTED SHAFT WALL FOR FIRE SEPARATION E120 - Shaft Wall 2x25 mm Flameboard/from one side
	TO BE CONSTRUCTED WALL FOR FIRE SEPARATION E120 - 2x15 mm/from both sides
	TO BE CONSTRUCTED WALL FOR FIRE SEPARATION E120 - 2x15 mm Plasterboard/from one side
	TO BE CONSTRUCTED HALL WALL FOR FIRE SEPARATION E120 - One Layer
	TO BE DEMOLISHED EXISTING DOOR
	TO BE MOUNTED NEW FIRE DOOR
	TO BE REMOUNTED EXISTING DOOR

<input checked="" type="checkbox"/> FOR SYSTEM APPROVAL <input type="checkbox"/> FOR TENDER <input type="checkbox"/> FOR INSTALLATION <input type="checkbox"/> AS BUILT		
KEY PLAN		
	For System Approval	
Date	Explanation	
CLIENT 		
DESIGNER TASARIM, DANIŞMANLIK VE EĞİTİM HİZMETLERİ LTD.ŞTİ. Cetin EMEC Bulvarı 2. Cad. No : 37/4 A. ÖVEÇLER - 06460 ANKARA / TÜRKYE Tel : +90-312-472 62 88 Faks : +90-312-472 62 89 e-posta: info@karina.gen.tr		
TECH. CONSULTANCY : KARİNA	FIRE & LIFE SAFETY IMPROVEMENT OF FIRE& SMOKE COMPARTMENT FEATURES DRAWINGS	
SYSTEM DESIGN : KARİNA		
MATERIAL SUPPLY : -		
INSTALLATION : -		
APPROVAL : -	DRAWING NO : EVEX-SNS-KAR-105-AR-002	REV. 00
DATE : 08.11.2020		* / *
SCALE : 1/100	FILE NAME : C:\EVEX-SNS-KAR-104-105-106-107-AR	