


LEGEND AND MATERIAL LIST			
SYMBOL	DESCRIPTION	MANUFAC.	MODEL NO.
	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (INSIDE SUSPENDED CEILING)	*	*
	FIXED TEMP. AND RATE OF RISE HEAT DETECTOR (FIXED TEMPERATURE, 135/7,84°C)	*	*
	ADDRESSABLE PHOTOELECTRIC SMOKE AND HEAT COMBINED DETECTOR	*	*
	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (WEATHER PROOF)	*	*
	FIRE ALARM MANUAL STATION (h:120cm)	*	*
	FIRE ALARM MANUAL STATION (WEATHER PROOF, h:120cm)	*	*
	AUDIO - VISUAL ALARM DEVICE (W-2.4-20)	*	*
	AUDIO - VISUAL ALARM DEVICE (WEATHER PROOF, W-2.4-20) (h:240cm)	*	*
	MONITORING MODULE (C/W SURFACE MOUNT BOX)	*	*
	CONTROL MODULE	*	*
	POWER SUPPLY 24VDC	*	*
	FIRE ALARM PANEL	*	*
	GRAPHIC MONITORING SYSTEM	*	*
	END OF LINE POWER SUPERVISION RELAY (24VDC, C/W SURFACE MOUNT BOX)	*	*
	INITIATING DEVICE CABLING (7mm², FLAME RESISTIVE, SHIELDED)	*	*
	AUDIO-VISUAL INDICATING DEVICE CABLING (1.5mm², FE180)	*	*

\* WILL BE DETERMINED LATER - NOT APPLICABLE



FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 4  
(SCALE : 1/200)

<input checked="" type="checkbox"/> FOR SYSTEM APPROVAL <input type="checkbox"/> FOR TENDER <input type="checkbox"/> FOR INSTALLATION <input type="checkbox"/> AS BUILT	
KEY PLAN	
OO	29.01.2021 For System Approval
Date	Explanation
CLIENT	
EVEX GEORGIA HEATHCARE GROUP 40 Yedigöller Mahallesi 2. Kat No : 37/4 Tbilisi - GEORGIA Tel : +995 322 55 05 05	
DESIGNER	
KARİNA TASARIM, DANIŞMANLIK VE EĞİTİM HİZMETLERİ LTD.ŞTİ. OYUN EMECİ Mahallesi 2. Kat No : 37/4 A. ÖZGÜLER - 06460 ANKARA / TURKEY Tel : +90-312-472 62 88 Faks : +90-312-472 62 89 e-posta: info@karina.gr.tr	
TECH. CONSULTANCY : KARİNA	SUNSTONE HOSPITAL FIRE & LIFE SAFETY FIRE ALARM SYSTEM PLAN DRAWING LEVEL 4
SYSTEM DESIGN : KARİNA	
MATERIAL SUPPLY : -	
INSTALLATION : -	
APPROVAL : -	DRAWING NO : EVEX-SNST-KAR-706
DATE : 29.01.2021	
SCALE : 1/200	FILE NAME : C:\_EVEX-SNST-KAR-706*

