



1) DIMENSIONS IN THIS TABLE ARE DERIVED USING 225 PSI WATER PRESSURE AND FOR A SOIL OF SAND AND GRAVEL (THE BEARING AREA IS MULTIPLIED BY 0.5 ACC. TO TABLE-2 OF FM DS 3-10)



TECH. CONSULTANCY : KARINA	<div style="text-align: center;"> <p>SUNSTONE HOSPITAL</p> <p><b>FIRE PUMP ROOM</b></p> <p><b>INSTALLATION DETAILS</b></p> </div>		<div style="text-align: right;"> <p>REV. 00</p> <p>• / •</p> </div>		EVEX-SNST-KAR-MECH-602
SYSTEM DESIGN : KARINA					
MATERIAL SUPPLY : —					
INSTALLATION : —					
APPROVAL : —					
DATE : 05.11.2020		DRAWING NO : EVEX-SNST-KAR-MECH-602			
SCALE : 1/100	FILE NAME : C:\_EVEX-SNST-KAR-MECH-602+				