


FIRE ALARM SYSTEM PLAN DRAWING – LEVEL 6
(SCALE : 1/200)

LEGEND AND MATERIAL LIST			
SYMBOL	DESCRIPTION	MANUFAC.	MODEL NO.
	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (INSIDE SUSPENDED CEILING)	*	*
	FIXED TEMP. AND RATE OF RISE HEAT DETECTOR (FIXED TEMPERATURE, 135/70°C)	*	*
	ADDRESSABLE PHOTOELECTRIC SMOKE AND HEAT COMBINED DETECTOR	*	*
	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (WEATHER PROOF)	*	*
	FIRE ALARM MANUAL STATION (h:120cm)	*	*
	FIRE ALARM MANUAL STATION (WEATHER PROOF, h:120cm)	*	*
	AUDIO – VISUAL ALARM DEVICE (W-2.4-20)	*	*
	AUDIO – VISUAL ALARM DEVICE (WEATHER PROOF, W-2.4-20) (h:240cm)	*	*
	MONITORING MODULE (C/W SURFACE MOUNT BOX)	*	*
	CONTROL MODULE	*	*
	POWER SUPPLY 24VDC	*	*
	FIRE ALARM PANEL	*	*
	GRAPHIC MONITORING SYSTEM	*	*
	END OF LINE POWER SUPERVISION RELAY (24VDC, C/W SURFACE MOUNT BOX)	*	*
	INITIATING DEVICE CABLING (7mm ² , FLAME RESISTIVE, SHIELDED)	*	*
	AUDIO-VISUAL INDICATING DEVICE CABLING (1.5mm ² , FE180)	*	*

* WILL BE DETERMINED LATER - NOT APPLICABLE



KEY PLAN

- FOR SYSTEM APPROVAL
- FOR TENDER
- FOR INSTALLATION
- AS BUILT

29.01.2021 For System Approval

Date Explanation

CLIENT

EVEX GEORGIA HEATHCARE GROUP
40 Yedigöller Mahallesi
Tbilisi – GEORGIA
Tel : +995 322 55 05 05

DESIGNER **KARİNA** TASARIM, DANIŞMANLIK VE EĞİTİM HİZMETLERİ LTD.ŞTİ.
ÖZEL TİMÇİ Mahallesi 2. Cad. No : 37/A
A. ÖZGÜLER – 06460 ANKARA / TÜRKİYE
Tel : +90-312-472 62 88 Faks : +90-312-472 62 89 e-posta: info@karina.gen.tr

TECH. CONSULTANCY : KARİNA
SYSTEM DESIGN : KARİNA
MATERIAL SUPPLY : –
INSTALLATION : –

APPROVAL : –
DATE : 29.01.2021

SCALE : 1/200

SUNSTONE HOSPITAL
FIRE & LIFE SAFETY
FIRE ALARM SYSTEM
PLAN DRAWING
LEVEL 6

DRAWING NO : EVEX-SNST-KAR-708

FILE NAME : C:_EVEX-SNST-KAR-708*

