





















2 NEW CONSTRUCTION PLAN - FIRST FLOOR #105-AR-001
1/100




WALL DETAIL – Connection to the side solid wall

WALL DETAIL – Connection to the ceiling

④ SHAFT WALL DETAIL FOR FIRE SEPARATION EI120/from one side

- | LEGEND AND MATERIAL LIST | |
|---|---|
| SYMBOL | DESCRIPTION |
|  | TO BE DEMOLISHED 60x60 GRID SUSPENDED CEILING |
|  | TO BE MOUNTED 60x60 GRID SUSPENDED CEILING |
|  | TO BE DEMOLISHED PVC HYGENIC SUSPENDED CEILING |
|  | TO BE MOUNTED PVC HYGENIC SUSPENDED CEILING |
|  | TO BE DEMOLISHED PLASTERBOARD SUSPENDED CEILING |
|  | TO BE MOUNTED PLASTERBOARD SUSPENDED CEILING |
|  | TO BE CLOSED HOLE BY BIMS WALL |
|  | TO BE DEMOLISHED EXISTING PLASTERBOARD WALL |
|  | TO BE DEMOLISHED EXISTING CERAMIC TILE |
|  | TO BE CONSTRUCTED PLASTERBOARD WALL WITHOUT FIRE RATING |
|  | TO BE CONSTRUCTED CERAMIC TILE |
|  | TO BE CONSTRUCTED COMPARTMENT WALL FOR FIRE SEPARATION E160 - 2x12,5 mm /from both sides |
|  | TO BE CONSTRUCTED SHAFT WALL FOR FIRE SEPARATION E120 - Shaft Wall 2x25 mm Flameboard/from one side |
|  | TO BE CONSTRUCTED WALL FOR FIRE SEPARATION E120 - 2x15 mm/from both sides |
|  | TO BE CONSTRUCTED WALL FOR FIRE SEPARATION E60 - 2x15 mm Plasterboard/from one side |
|  | TO BE CONSTRUCTED HALL WALL FOR FIRE SEPARATION E60 - One Layer |
|  | TO BE DEMOLISHED EXISTING DOOR |
|  | TO BE MOUNTED NEW FIRE DOOR |
|  | TO BE REMOUNTED EXISTING DOOR |



Date	Explanation
------	-------------

CLIENT



KARİNA TASARIM, DANIŞMANLIK VE EĞİTİM HİZMETLERİ LTD.ŞTİ.

Çetin EMEÇ Bulvarı 2. Cad. No : 37/4
A. ÖVEÇLER - 06460 ANKARA / TURKEY
Tel : +90-312-472 62 88 Faks : +90-312-472 62 89

Tel : +90-312-472 62 88 Faks : +90-312-472 62 89 e-posta: info@karina.gen.tr

TECH. CONSULTANCY : KARINA

SYSTEM DESIGN : KARINA

MATERIAL SUPPLY : -

[illegible]

APPROVAL : -

DATE	: 08.11.2020
------	--------------

FIRE & LIFE SAFETY
IMPROVEMENT OF FIRE& SMOKE
COMPARTMENT FEATURES DRAWINGS

	DRAWING NO : EVERY SNS KAP 105 AB
---	--------------------------------------

FILE NAME : C:\EVEX-SNS-KAR-104-105-106-107-AR*

1	REV.	00
	* / *	

EVEX-SNS-KAR-104-105-106-107-AR