






NOM.DIAMETER	OUTSIDE DIAMETER	INSIDE DIAMETER	WALL THICKNESS
DN 110	110,0 mm	90,0 mm	10,0 mm
DN 180	180,0 mm	147,2 mm	16,4 mm
DN 250	225 mm	179,8 mm	22,7 mm

NOM.DIAMETER	OUTSIDE DIAMETER	INSIDE DIAMETER	WALL THICKNESS
DN 100 (4")	114.3 mm	105.3 mm	4.50 mm
DN 150 (6")	165.1 mm	155.4 mm	5.00 mm
DN200 (8")	219.1 mm	207.9 mm	5.60 mm

ALL STEEL PIPES SHALL CONFORM TO TS EN 10217-1 AND TS EN 10217-1 WELDED BLACK STEEL.

1) DIMENSIONS IN THIS TABLE ARE DERIVED USING 225 PSI WATER PRESSURE AND FOR A SOIL OF SAND AND GRAVEL (THE BEARING AREA IS MULTIPLIED BY 0.5 ACC. TO TABLE-2 OF FM DS 3-10)



EVEX-SNSTN-KAR-MECH-301			
-------------------------	--	--	--