




FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 6
(SCALE : 1/200)



FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 7
(SCALE : 1/200)



FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 8
(SCALE : 1/200)




FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 9
(SCALE : 1/200)

LEGEND AND MATERIAL LIST			
SYMBOL	DESCRIPTION	MANUFAC.	MODEL NO.
Ⓟ	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
Ⓟ _{ceiling}	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (INSIDE SUSPENDED CEILING)	*	*
Ⓜ	FIXED TEMP. AND RATE OF RISE HEAT DETECTOR (FIXED TEMPERATURE, 135F/50°C)	*	*
Ⓧ	ADDRESSABLE PHOTOELECTRIC SMOKE AND HEAT COMBINED DETECTOR	*	*
Ⓟ _{duct}	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
Ⓟ _{dp}	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (WEATHER PROOF)	*	*
Ⓜ _{hdc}	LINEAR HEAT DETECTOR MODULE (C/W SURFACE MOUNT BOX)	*	*
~~~~~	LINEAR HEAT DETECTOR CABLE, 155V, TYPE EPC	*	*
Ⓜ	FIRE ALARM MANUAL STATION (h=120cm)	*	*
Ⓜ _{dp}	FIRE ALARM MANUAL STATION (WEATHER PROOF, h=120cm)	*	*
Ⓜ _{av}	AUDIO - VISUAL ALARM DEVICE (W-2.4-20)	*	*
Ⓜ _{avdp}	AUDIO - VISUAL ALARM DEVICE (WEATHER PROOF, W-2.4-20) (h=240cm)	*	*
Ⓜ	MONITORING MODULE (C/W SURFACE MOUNT BOX)	*	*
Ⓜ	CONTROL MODULE	*	*
Ⓜ _{ps}	POWER SUPPLY 24VDC	*	*
Ⓜ _{fap}	FIRE ALARM PANEL	*	*
Ⓜ _{gms}	GRAPHIC MONITORING SYSTEM	*	*
Ⓜ _{elr}	END OF LINE POWER SUPERVISION RELAY (24VDC, C/W SURFACE MOUNT BOX)	*	*
—	INITIATING DEVICE CABLING (1mm ² , FLAME RESISTIVE, SHIELDED)	*	*
—	AUDIO-VISUAL INDICATING DEVICE CABLING (1.5mm ² , FE180)	*	*

* WILL BE DETERMINED LATER - NOT APPLICABLE

- FOR SYSTEM APPROVAL
- FOR TENDER
- FOR INSTALLATION
- AS BUILT




DO	22.02.2021	For System Approval
Date		Explanation

CLIENT  
**EVEX GEORGIA HEALTHCARE GROUP**  
40. Yedigöller Mahallesi  
Tbilisi - GEORGIA  
Tel: +995 322 55 05 05

DESIGNER  
**KARİNA** TASARIM, DANIŞMANLIK VE EĞİTİM HİZMETLERİ LTD.ŞTİ.  
C/500 Etiler Sokakı No: 33/4  
A. ÖZGÜLER - 06460 ANKARA / TÜRKİYE  
Tel: +90-312-472 62 88 Faks: +90-312-472 62 89 e-posta: info@karina.gen.tr

TECH. CONSULTANCY : KARİNA	<b>DEKA HOSPITAL</b> FIRE & LIFE SAFETY PROVIDE ADDITIONAL PARTIAL COVERAGE FIRE ALARM SYSTEM PLAN DRAWINGS LEVEL 9, 8, 7 & 6
SYSTEM DESIGN : KARİNA	
MATERIAL SUPPLY : -	
INSTALLATION : -	
APPROVAL : -	DRAWING NO : <b>EVEX-DK-KAR-706</b>
DATE : 22.02.2021	REV. NO : 00
SCALE : 1/200	FILE NAME : c:_VEX-DK-KAR-706



EVEX-DK-KAR-706