


LEGEND AND MATERIAL LIST			
SYMBOL	DESCRIPTION	MANUFAC.	MODEL NO.
P	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
AT	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (INSIDE SUSPENDED CEILING)	*	*
H	FIXED TEMP. AND RATE OF RISE HEAT DETECTOR (FIXED TEMPERATURE, 135F/50°C)	*	*
K	ADDRESSABLE PHOTOELECTRIC SMOKE AND HEAT COMBINED DETECTOR	*	*
L	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
O	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (WEATHER PROOF)	*	*
M	LINEAR HEAT DETECTOR MODULE (C/W SURFACE MOUNT BOX)	*	*
N	LINEAR HEAT DETECTOR CABLE, 155FT, TYPE EPC	*	*
Q	FIRE ALARM MANUAL STATION (h:120cm)	*	*
R	FIRE ALARM MANUAL STATION (WEATHER PROOF, h:120cm)	*	*
S	AUDIO - VISUAL ALARM DEVICE (W-2.4-20)	*	*
T	AUDIO - VISUAL ALARM DEVICE (WEATHER PROOF, W-2.4-20) (h:240cm)	*	*
U	MONITORING MODULE (C/W SURFACE MOUNT BOX)	*	*
V	CONTROL MODULE	*	*
W	POWER SUPPLY 24VDC	*	*
X	FIRE ALARM PANEL	*	*
Y	GRAPHIC MONITORING SYSTEM	*	*
Z	END OF LINE POWER SUPERVISION RELAY (24VDC, C/W SURFACE MOUNT BOX)	*	*
---	INITIATING DEVICE CABLE (1mm ² , FLAME RESISTIVE, SHIELDED)	*	*
---	AUDIO-VISUAL INDICATING DEVICE CABLE (1.5mm ² , FE180)	*	*

* WILL BE DETERMINED LATER - NOT APPLICABLE

FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 3
(SCALE : 1/200)

- FOR SYSTEM APPROVAL
- FOR TENDER
- FOR INSTALLATION
- AS BUILT




DO	22.02.2021	For System Approval
Date		Explanation

CLIENT
EVEK GEORGIA HEALTHCARE GROUP
40. Yildiz Mahallesi Ave
Tbilisi - GEORGIA
Tel: +995 322 55 05 05

DESIGNER
KARINA TASARIM, DANIŞMANLIK VE EĞİTİM HİZMETLERİ LTD.ŞTİ.
Caddesi EMEC Sokakı 2. Kat. No: 37/4
A. ÖZGÜLER - 06460 ANKARA / TÜRKİYE
Tel: +90-312-472 62 88 Faks: +90-312-472 62 89 e-posta: info@karina.gen.tr

TECH. CONSULTANCY	: KARINA	DEKA HOSPITAL FIRE & LIFE SAFETY PARTIAL COVERAGE FIRE ALARM SYSTEM PLAN DRAWINGS LEVEL 3
SYSTEM DESIGN	: KARINA	
MATERIAL SUPPLY	: -	
INSTALLATION	: -	

APPROVAL	: -	DRAWING NO : EVEK-DK-KAR-704	REV 00
DATE	: 22.02.2021		
SCALE	: 1/200	FILE NAME : c:_VDEX-DK-KAR-704*	• / •



EVEK-DK-KAR-704