


FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 5
(SCALE : 1/200)




FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 4
(SCALE : 1/200)

LEGEND AND MATERIAL LIST			
SYMBOL	DESCRIPTION	MANUFAC.	MODEL NO.
(P)	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
(AT)	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (INSIDE SUSPENDED CEILING)	*	*
(H)	FIXED TEMP. AND RATE OF RISE HEAT DETECTOR (FIXED TEMPERATURE, 135F/50°C)	*	*
(K)	ADDRESSABLE PHOTOELECTRIC SMOKE AND HEAT COMBINED DETECTOR	*	*
(I)	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
(I _{WP})	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (WEATHER PROOF)	*	*
(HSD)	LINEAR HEAT DETECTOR MODULE (C/W SURFACE MOUNT BOX)	*	*
~~~~~	LINEAR HEAT DETECTOR CABLE, 155FT, TYPE EPC	*	*
(M)	FIRE ALARM MANUAL STATION (h:120cm)	*	*
(M _{WP} )	FIRE ALARM MANUAL STATION (WEATHER PROOF, h:120cm)	*	*
(A)	AUDIO - VISUAL ALARM DEVICE (W-2.4-20)	*	*
(A _{WP} )	AUDIO - VISUAL ALARM DEVICE (WEATHER PROOF, W-2.4-20) (h:240cm)	*	*
(W)	MONITORING MODULE (C/W SURFACE MOUNT BOX)	*	*
(C)	CONTROL MODULE	*	*
(PS)	POWER SUPPLY 24VDC	*	*
(FAP)	FIRE ALARM PANEL	*	*
(GMS)	GRAPHIC MONITORING SYSTEM	*	*
(ELSR)	END OF LINE POWER SUPERVISION RELAY (24VDC, C/W SURFACE MOUNT BOX)	*	*
---	INITIATING DEVICE CABLEING (1mm ² , FLAME RESISTIVE, SHIELDED)	*	*
---	AUDIO-VISUAL INDICATING DEVICE CABLEING (1.5mm ² , FE180)	*	*

* WILL BE DETERMINED LATER      - NOT APPLICABLE

- FOR SYSTEM APPROVAL
- FOR TENDER
- FOR INSTALLATION
- AS BUILT




DO	22.02.2021	For System Approval
Date		Explanation

CLIENT  
**EVEK GEORGIA HEALTHCARE GROUP**  
40. Yedigöller Mahallesi  
Tbilisi - GEORGIA  
Tel: +995 322 55 05 05

DESIGNER  
**KARİNA TASARIM, DANIŞMANLIK VE EĞİTİM HİZMETLERİ LTD.ŞTİ.**  
Ordu İNCE Mahallesi 2. Cad. No: 37/4  
A. ÖZGÜLER - 06460 ANKARA / TÜRKİYE  
Tel: +90-312-472 62 88 Faks: +90-312-472 62 89 e-posta: info@karina.gen.tr

TECH. CONSULTANCY :	KARİNA	<b>DEKA HOSPITAL</b> FIRE & LIFE SAFETY PROVIDE ADDITIONAL PARTIAL COVERAGE FIRE ALARM SYSTEM PLAN DRAWINGS LEVEL 5 & 4	REV NO / .
SYSTEM DESIGN :	KARİNA		
MATERIAL SUPPLY :	-		
INSTALLATION :	-		
APPROVAL :	-		
DATE :	22.02.2021	DRAWING NO : EVEX-DK-KAR-705	REV 00
SCALE :	1/200	FILE NAME : c:_EVEX-DK-KAR-705	



EVEX-DK-KAR-705