



SEE EYEX-DEKA-KAR-MEDH-801
 FOR TECHNICAL AND BATTERY CHARGING ROOMS
 FOR C-1-1 (200VDC) GASEOUS SUPPRESSION SYSTEM
 PLAN AND DETAIL DRAWINGS



FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 2
 (SCALE : 1/200)




FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 1
 (SCALE : 1/200)

LEGEND AND MATERIAL LIST			
SYMBOL	DESCRIPTION	MANUFAC.	MODEL NO.
Ⓟ	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
Ⓟ _{ceiling}	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (INSIDE SUSPENDED CEILING)	*	*
Ⓟ _{temp}	FIXED TEMP. AND RATE OF RISE HEAT DETECTOR (FIXED TEMPERATURE, 135F/50°C)	*	*
Ⓟ _{heat}	ADDRESSABLE PHOTOELECTRIC SMOKE AND HEAT COMBINED DETECTOR	*	*
Ⓟ _{duct}	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
Ⓟ _{weather}	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (WEATHER PROOF)	*	*
Ⓟ _{linear}	LINEAR HEAT DETECTOR MODULE (C/W SURFACE MOUNT BOX)	*	*
Ⓟ _{cable}	LINEAR HEAT DETECTOR CABLE, 155FT, TYPE EPC	*	*
Ⓟ _{ms}	FIRE ALARM MANUAL STATION (h:120cm)	*	*
Ⓟ _{ms-weather}	FIRE ALARM MANUAL STATION (WEATHER PROOF, h:120cm)	*	*
Ⓟ _{audio}	AUDIO - VISUAL ALARM DEVICE (W-2.4-20)	*	*
Ⓟ _{audio-weather}	AUDIO - VISUAL ALARM DEVICE (WEATHER PROOF, W-2.4-20) (h:240cm)	*	*
Ⓟ _{monitoring}	MONITORING MODULE (C/W SURFACE MOUNT BOX)	*	*
Ⓟ _{control}	CONTROL MODULE	*	*
Ⓟ _{power}	POWER SUPPLY 24VDC	*	*
Ⓟ _{fap}	FIRE ALARM PANEL	*	*
Ⓟ _{fdcp}	FIRE DETECTION AND EXTINGUISHING CONTROL PANEL	*	*
Ⓟ _{gms}	GRAPHIC MONITORING SYSTEM	*	*
Ⓟ _{elr}	END OF LINE POWER SUPERVISION RELAY (24VDC, C/W SURFACE MOUNT BOX)	*	*
Ⓟ _{initiating}	INITIATING DEVICE CABLEING (1mm ² , FLAME RESISTING, SHIELDED)	*	*
Ⓟ _{audio-visual}	AUDIO-VISUAL INDICATING DEVICE CABLEING (1.5mm ² , FE180)	*	*

* WILL BE DETERMINED LATER - NOT APPLICABLE

- FOR SYSTEM APPROVAL
- FOR TENDER
- FOR INSTALLATION
- AS BUILT




KEY PLAN

DO	22.02.2021	For System Approval
Date		Explanation

CLIENT
EVEX GEORGIA HEALTHCARE GROUP
 40. Yildiz Fıstıklıoğlu Ave
 Tbilisi - GEORGIA
 Tel : +995 322 55 05 05

DESIGNER
KARİNA TASARIM, DANIŞMANLIK VE EĞİTİM HİZMETLERİ LTD.ŞTİ.
 Çiğdem Sokağı 2. Cad. No : 37/4
 A. ÖZGÜLER - 06460 ANKARA / TÜRKİYE
 Tel : +90-312-472 62 88 Faks : +90-312-472 62 89 e-posta: info@karina.gen.tr

TECH. CONSULTANCY :	KARİNA	DEKA HOSPITAL FIRE & LIFE SAFETY PROVIDE ADDITIONAL PARTIAL COVERAGE FIRE ALARM SYSTEM PLAN DRAWINGS LEVEL 2 & 1
SYSTEM DESIGN :	KARİNA	
MATERIAL SUPPLY :	-	
INSTALLATION :	-	
APPROVAL :	-	
DATE :	22.02.2021	DRAWING NO : EYEX-DK-KAR-703
SCALE :	1/200	FILE NAME : c:_EYEX-DK-KAR-703



EYEX-DK-KAR-703