



LEGEND AND MATERIAL LIST			
SYMBOL	DESCRIPTION	MANUFAC.	MODEL NO.
	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
	ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (WSDE SUSPENDED CEILING)	*	*
	FIXED TEMP. AND RATE OF RISE HEAT DETECTOR (FIXED TEMPERATURE, 135°F/58°C)	*	*
	ADDRESSABLE PHOTOELECTRIC SMOKE AND HEAT COMBINED DETECTOR	*	*
	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR	*	*
	DUCT TYPE ADDRESSABLE PHOTOELECTRIC SMOKE DETECTOR (WEATHER PROOF)	*	*
	LINEAR HEAT DETECTOR MODULE (C/W SURFACE MOUNT BOX)	*	*
	LINEAR HEAT DETECTOR CABLE, 155V, TYPE EPC	*	*
	FIRE ALARM MANUAL STATION (h=120cm)	*	*
	FIRE ALARM MANUAL STATION (WEATHER PROOF, h=120cm)	*	*
	AUDIO - VISUAL ALARM DEVICE (W-2.4-20)	*	*
	AUDIO - VISUAL ALARM DEVICE (WEATHER PROOF, W-2.4-4-20) (h=240cm)	*	*
	MONITORING MODULE (C/W SURFACE MOUNT BOX)	*	*
	CONTROL MODULE	*	*
	POWER SUPPLY 24VDC	*	*
	FIRE ALARM PANEL	*	*
	GRAPHIC MONITORING SYSTEM	*	*
	END OF LINE POWER SUPERVISION RELAY (24VDC, C/W SURFACE MOUNT BOX)	*	*
	INITIATING DEVICE CABLING (1mm², FLAME RESISTANT, SHIELDED)	*	*
	AUDIO-VISUAL INDICATING DEVICE CABLING (1.5mm², FE180)	*	*

* WILL BE DETERMINED LATER


- NOT APPLICABLE



FIRE ALARM SYSTEM PLAN DRAWING - LEVEL 0
(SCALE : 1/200)



FIRE ALARM SYSTEM PLAN DRAWING - LEVEL -1
(SCALE : 1/200)



FIRE PUMP ROOM MONITORING MODULES DETAILS
(SCALE : N.T.S.)

<input checked="" type="checkbox"/> FOR SYSTEM APPROVAL <input type="checkbox"/> FOR TENDER <input type="checkbox"/> FOR INSTALLATION <input type="checkbox"/> AS BUILT	
KEY PLAN	
OO	22.02.2021
Date	For System Approval
Explanation	
CLIENT	
EVEK GEORGIA HEATHCARE GROUP	
40 Yedigöller Baharı 2. Kat No : 37/A Talihi - GEORGIA Tel : +995 322 55 05 05	
DESIGNER	
KARINA TASARIM, DANIŞMANLIK VE EĞİTİM HİZMETLERİ LTD.ŞTİ.	
40 Yedigöller Baharı 2. Kat No : 37/A A. ÖZGÜLER - 06460 ANKARA / TÜRKİYE Tel : +90-312-472 62 88 Faks : +90-312-472 62 89 e-posta: info@karina.gen.tr	
TECH. CONSULTANCY : KARINA	DEKA HOSPITAL FIRE & LIFE SAFETY PROVIDE ADDITIONAL PARTIAL COVERAGE FIRE ALARM SYSTEM PLAN DRAWINGS LEVEL 0 & -1
SYSTEM DESIGN : KARINA	
MATERIAL SUPPLY : -	
INSTALLATION : -	
APPROVAL : -	DRAWING NO : EVEX-DK-KAR-702
DATE : 22.02.2021	
SCALE : 1/200	FILE NAME : C:_EVEX-DK-KAR-702*

