



| Item | Quantity | Description | Detail |
|------|----------|-----------------------|--------------------------|
| 1 | 1 | COVER | |
| 2 | 3 | EARTHING TERMINAL | |
| 3 | 1 | FILLING PIPE | |
| 4 | 3 | H.V. BUSHINGS | 10NF250 |
| 5 | 1 | INTEG.SAFETY DETECTOR | RIS |
| 6 | 8 | L.V. BUSHINGS | DT1/2000 |
| 7 | 2 | LIFTING LUG | for TANK |
| 8 | 1 | OIL VALVE | 1" DRAIN, for TANK |
| 9 | 1 | PRESSURE SAFETY VALVE | T-10 |
| 10 | 2 | PROFILE | for TRANSPORT PROTECTION |
| 11 | 1 | PT100 DEVICE | |
| 12 | 1 | RATING PLATE | |
| 13 | 4 | ROLLER ASSEMBLY | D=200mm |
| 14 | 1 | TANK | |
| 15 | 1 | TAP CHANGER | DE-ENERGIZED |
| 16 | 2 | THERMOMETER POCKET | SPARE |

TRANSFORMER IS TRANSPORTED WITH OIL

| | |
|------------------------|---------------|
| RATED POWER KVA | 2500 |
| RATED VOLTAGE V | 10000/400 |
| FREQUENCY HZ | 50 |
| VECTOR GROUP | Dyn11 |
| COOLING CLASS | ONAN |
| MASS OF ACTIVE PART Kg | 2515 |
| MASS OF OIL Kg | 1028 |
| MASS OF TRANSFORMER Kg | 5055 |
| PAINT COLOR | RAL 7033 C3-M |

| | | | | | | | | |
|-------------|----------------------------|-------|-------|------|----------|----------|----------|------------------------|
| Zone | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 |
| Rev | | | | | | | | |
| Description | ABB Elektrik Sanayi A.S. | | | | | | | |
| Date | | | | | | | | |
| Approved | | | | | | | | |
| Prepared | Y. TUNALI KAYIR 27/02/2018 | | | | | | | |
| Approved | ZS 27/02/2018 | | | | | | | |
| Rev. | 0 | Scale | 0.038 | Mass | FA000365 | Based On | FA000365 | Responsible Department |
| | | | | | | | | Takeover Department |

| | |
|----------------|------------------|
| Classification | TSPH-18040 |
| Title | CUSTOMER OUTLINE |
| Document No. | 1LTR18040A0 |
| Lang | EN |
| Cont. | 1 |
| Sheet | 1 |